

ADDENDUM NO. 1
DEWATERING SYSTEM UPGRADE FOR WWTP PROJECT
APRIL 21, 2010

PROJECT TITLE: City of Buellton: DEWATERING SYSTEM UPGRADE FOR WWTP PROJECT

The following changes additions and clarifications are hereby made part of the contract documents for the above referenced project and shall be taken into account in the preparation of all proposals and the execution of all work. Work shall conform to the requirements of the original contract documents and addenda wherever they apply.

All bidders shall acknowledge receipt of this addendum on the bid proposal form.

Modify the specification as follows:

Section D2.35 EQUIPMENT TESTING, b. MANUFACTURERS SERVICE REPRESENTATIVE, 1.

Deleted *i) One day (minimum) during erection, ii) Two days (minimum) during start up*

and replace with:

i) Four days (minimum) during erection and start up

ii) Three days (minimum) for operator training.

END OF ADDENDUM