

**CITY OF BUELLTON WATER SYSTEM: CONSUMER CONFIDENCE REPORT – JUNE 2019**

PRIMARY STANDARDS-Mandatory Health-Related Standards								
Parameter	Units	State	PHG	TREATED		SOURCE		Major Sources of Drinking Water
				Range	CCWA	STATE	GROUND	
Clarity		MCL	(MCLG)	Average	PPWTP	WATER	WATER	
Combined Filter Effluent	NTU	TT=< NTU EVERY 4HOURS			0 - 0.13	NA	0.17 - 0.24	Soil runoff
Turbidity		TT=95% OF SAMPLES <0.3 NTU			100%	NA	0.2	
MICROBIOLOGICAL								
Total Coliform Bacteria (Distr. System-Wide)	-	5.00%	0	Range	0%	NA	0 positives	Naturally present in the environment
				Average	0.00%	NA	0 positives	
Fecal Coliform E. coli (Distr. System-Wide)	-	-	0	Range	0 positives	NA	0 positives	Human and animal fecal waste
				Average	0 positives	NA	0 positives	
INORGANIC CHEMICALS								
Aluminum	ppm	1	0.6	Range	ND-0.095	ND-0.14	ND	Residue from water treatment process; Erosion of natural deposits
				Average	0.058	0.088	ND	
Arsenic (Total)	ppb	10	0.004	Range	ND	ND	ND - 2.2	Erosion of natural deposits; glass & electronics production wastes
				Average	ND	ND	0.55	
Nitrate (as N)	ppm	10	10	Range	ND	ND	ND - 0.49	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
				Average	ND	ND	0.12	
Fluoride	ppm	2	1	Range	ND	ND	0.28 - 0.34	Runoff & leaching from fertilizer use; sewage; erosion of natural deposits
				Average	ND	ND	0.31	
RADIONUCLIDES (f)								
Gross Alpha	pCi/L	15	0	Range	ND	ND	6.55 - 7.05	Erosion of Natural deposits
				Average	ND	ND	6.9	
Uranium	pCi/L	20	0.43	Range	NA	NA	5.3 - 6.7	Erosion of Natural deposits
				Average	NA	NA	5.9	
DISTRIBUTION SYSTEM MONITORING								
TOTAL CHLORINE RESIDUAL	ppm	MRDL=4	MRDLG=4	Range	1.76 - 3.2	NA	.85-1.75	Measurement of the disinfectant used in the production of drinking water
				Average	2.32	NA	1.46	
Total Trihalomethanes	ppb	80	n/a	Range	27 - 50	NA	1.8-4.7	By-product of drinking water Chlorination
				Average	39	NA	3.3	
Haloacetic acids	ppb	60	NA	Range	8.3 - 12	NA	1.5-2.8	By-product of drinking water Chlorination
				Average	10	NA	2.2	
SECONDARY STANDARDS-Aesthetic Standards								
Chloride	ppm	500	NA	Range	39 - 140	34 - 142	60-89	Runoff/leaching from natural deposits; seawater influence
				Average	81	78	75	
Color (ACU)	ACU	15	NA	Range	ND	30	ND	Naturally occurring organic materials
				Average	ND	30	ND	
Iron	ppb	300	NA	Range	ND	0.17	ND	Leaching from natural deposits; Industrial wastes
				Average	ND	0.17	ND	
Manganese	ppb	50	NA	Range	ND	22	ND-.011	Leaching from natural deposits
				Average	ND	22	0.002	
Odor Threshold	TON	3	NA	Range	2	2	ND	Naturally occurring organic materials
				Average	2	2	ND	
Specific Conductance	Us/CM	1600	NA	Range	294 - 592	105-702	1100-1400	Substances that form ions when in seawater influence water;
				Average	481	451	1275	
Sulfate	ppm	500	NA	Range	55	30	230-330	Runoff/leaching from natural deposits; industrial wastes
				Average	55	30	293	
Total Dissolved Solids	ppm	1000	NA	Range	220	190	740-940	Runoff/leaching from natural deposits; seawater influence
				Average	220	190	858	
Turbidity (Monthly)	NTU	5	NA	Range	ND - 0.12	ND - 10.2	.13-.41	Soil runoff
				Average	0.05	1.73	0.27	
UNREGULATED SUBSTANCES - Additional Parameters								
Alkalinity (Total)	ppm	NA	NA	Range	44 - 78	46 - 86	300-320	Runoff/leaching from natural deposits; seawater influence
				Average	61	66	308	
Calcium	ppm	NA	NA	Range	14	15	110-120	Runoff/leaching from natural deposits; seawater influence
				Average	14	15	113	
Hardness (Total Hardness)	ppm	NA	NA	Range	62 - 140	58 - 142	480-590	Leaching from natural deposits
				Average	96	96	543	
Heterotrophic Plate Count	CFU/ml	TT	NA	Range	0 - 1	NA	ND-21	Naturally present in the environment
				Average	0	NA	4.25	
Magnesium	ppm	NA	NA	Range	7.7	8	51-72	Runoff/leaching from natural deposits; seawater influence
				Average	7.7	8	64	
pH	pH	NA	NA	Range	7.8 - 8.7	7.6 - 9.45	7.7-7.8	Runoff/leaching from natural deposits; seawater influence
				Average	8.3	8.5	7.78	
Potassium	ppm	NA	NA	Range	1.8	1.9	2.3-3.0	Runoff/leaching from natural deposits; seawater influence
				Average	1.8	1.9	2.73	
Sodium	ppm	NA	NA	Range	40	33	59-75	Runoff/leaching from natural deposits; seawater influence
				Average	40	33	67	
Total Organic Carbon (TOC)	ppm	TT	NA	Range	1.6 - 3.2	2.4 - 5	1.3-2.2	Various naturals and manmade sources
				Average	2.1	3.3	1.9	
LEAD AND COPPER RULE								
	No. of Samples Collected	90th %tile Detected		No. Sites exceeding AL	AL	MCLG	Typical Source of Contaminant	
Lead (PPB)	20	5.6		0	ND	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits	
Copper (PPM)	20	0.79		0	ND	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching wood preservatives	
MONITORING VIOLATIONS								
None.								
What happened / What is Being Done:								
Data represented on these tables covers the reporting period of January - December 2018. Consumer Confidence Report is printed on June 2019.								

**Definitions:**

**ACU** – Apparent Color Units.  
**AL** – Regulatory Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.  
**CFU/ml** – Colony Forming Units per milliliter.  
**MCL** – Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.  
**MCLG** – Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the US Environmental Protection Agency (USEPA).  
**MRDL** – Maximum Residual Disinfectant Level  
**NA** – Not applicable.  
**ND** – Not detectable at testing limit.  
**NTU** – Nephelometric Turbidity Unit: A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.  
**pCi/L** – picocuries per liter (a measure of radiation)  
**PDWS** – Primary Drinking Water Standards: MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.  
**PHG** – Public Health Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency (CalEPA).  
**ppb** – parts per billion or micrograms per liter (ug/L).  
**ppm** – parts per million or milligrams per liter (mg/L).  
**SDWS** – Secondary Drinking Water Standards: MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.  
**TON** – Threshold Odor Number  
**TT** – Treatment Technique  
**Us/cm** – umhos/cm – unit of specific conductance of water.

**Substances that Could Be in Water** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, USEPA and the CDPH prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. CDPH regulations also establish limits for contaminants in bottled water that must provide the same protection for public health. Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

- \***Inorganic contaminants** such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- \***Microbial contaminants** such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- \***Organic chemical contaminants** including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- \***Pesticides and herbicides** which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- \***Radioactive contaminants** which can be naturally-occurring or be the result of oil and gas production and mining activities.

**Community Participation:**

The City Council holds regularly scheduled Council meetings on the second and fourth Thursdays of every month at 6:00 pm at the Council Chambers located at: 140 W. Highway 246.

**Questions** If you have any questions about this report or your water, please contact the City of Buellton Public Works Department, Rose Hess at: 805-686-0137

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.**

**Important Health Information** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects are available from the Safe Drinking Water Hotline: 800-426-4791 or <http://water.epa.gov/drink/hotline>.

**Buellton Water Sources and Treatment** The City of Buellton’s source of supply is from four groundwater wells (Buellton Uplands and Santa Ynez River Underflow) and is supplemented by the State Water Project (from Northern California via aqueduct). Groundwater is treated using media filtration as well as disinfection. The annual groundwater production of clean drinking water in 2016 for the City was 1044 acre feet, or 0.9 million gallons per day.

**Source Water Assessments** In accordance with the State’s Drinking Water Source Assessment Program, a Source Water Assessment for all four of the City’s wells was completed in March 2001 and updated in May 2011. These assessments include a delineation of the areas around a drinking water source through which contaminants might move and reach that drinking water supply; an inventory of possible contaminating activities (PCAs) that might lead the release of microbiological or chemical contaminants within the delineated area; and a determination of the PCAs to which the drinking water source is most vulnerable. Copies of these assessments may be viewed at: California Department of Public Health (CDPH) District 6 Field Operations: 1180 Eugenia Place, Suite 200, Carpinteria, CA 93013 or online at: <http://www.cdph.ca.gov/certific/drinkingwater/pages/dwsap.aspx>

**CCR Going Paperless** Historically, the City of Buellton has mailed its customers a printed copy of the CCR to comply with the Safe Drinking Water Act (SDWA). On February 21, 2013, the California Department of Public Health expanded its interpretation of the SDWA to allow for electronic delivery of the CCR. The electronic delivery will allow us to reduce consumption of paper and minimize potential printing costs. In 2015 the City’s CCR has not been mailed, and has been available on our City webpage [www.cityofbuellton.com/public-works.asp](http://www.cityofbuellton.com/public-works.asp) Hard copies will be located at City Hall and the Public Library. Hard copies will only be mailed upon request.